



CLINTON VOLUNTEER FIRE DEPARTMENT

35 EAST MAIN STREET

CLINTON, CONNECTICUT 06413

PHONE (860) 669-8131 FAX (860) 669-7650

March 14, 2018

To: Planning and Zoning Commission

From: Brian Manware
Chief of Department

Re: P&Z SE/CAM 18-007
18 Nod Rd

I have reviewed the current application documentation as submitted. The CVFD requests that we are consulted with in regards the installation of a fire alarm system at this location. We also request the installation of an EAS Box for emergency access to the building. In discussion with the property owner, as long as it is approved by the fire marshal, we would like to see that the alarm panel is located in a utility room, not in one of the occupied units. We also have no objection if both buildings are tied into the same system, provided the outbuilding is zoned and labeled as such. I have no additional questions, comments or concerns at this time.

"Smoke Detectors Save Lives"

FIRE PREVENTION — RESCUE — MARINE RESCUE — EMERGENCY MEDICAL SERVICE