



ENGINEER  
CONSULT  
MANAGE

DELIVERING YOUR PROJECTS WITH INNOVATION & INTEGRITY

## ADDENDUM NO. 1

Clinton High School Sidewalk Extension  
Clinton CT

**Bid #R81-MSP-2018**

June 21, 2018

Ladies and Gentlemen:

This is an addendum to the above bid. Special attention should be given to this addendum to preserve the validity of any proposal submitted in response to this request. Bid responses must include page two executed by the Bidder.

This addendum includes a total of 2 pages.

This addendum must be acknowledged and included with your sealed bids.

Sincerely,

DIVERSIFIED TECHNOLOGY CONSULTANTS

John Treichel  
Project Manager

cc: Peter Neff

DIVERSIFIED TECHNOLOGY CONSULTANTS (DTC)

2321 WHITNEY AVENUE SUITE 301 HAMDEN CT 06518

203 239 4200 PH [www.teamdtc.com](http://www.teamdtc.com)

**ADDENDUM NO. 1**

Clinton High School Sidewalk Extension  
Clinton CT

The following are Q&A received by the 19 June deadline;

1. What are the bonding requirements for the project?  
**10% Bid bond and 100% Performance & Payment bonds.**
2. What is the anticipated start and finish dates for this project?  
**If the project is within budget, almost immediately. If over; additional funds will be sought (so potentially a short delay in starting) if the total bid is under the current State of CT DOL \$1,000,000 threshold regarding prevailing wage. If not; project will be re-bid requiring prevailing wage rates. Duration is 150 cc days.**
3. Under item #'s 0601651A & 0601652A, #5 General Design Requirements, Part J states the maximum allowable bearing pressure of the soil shall be as shown on the contract drawings. I was not able to find this information. Please clarify. The geotechnical report did not seem to be in the electronic bid package.  
**The maximum allowable soil bearing pressure is identified in the geotechnical report now posted on the Town bid web-site.**
4. Sheet TS-1 shows 5" thick concrete sidewalk with 8" base. Sheet 36 detail 1 shows 9" sidewalk with 12" base. Please confirm which is correct?  
**Both as noted are correct. The added concrete noted (9") is where the concrete sidewalk extends thru a concrete driveway apron. There is only one location effected by same at the southerly end of the project. The remaining driveway aprons will be bituminous; 5" concrete sidewalks abutting.**
5. When is anticipated award and NTP as there is 150 cc days in the project and it appears this work will continue into the Spring or 2019?  
**As noted in question #2 response above it is the intent to move quickly with construction. Regardless of when project starts some work may need to be pushed until the Spring of 2019.**

*END OF ADDENDUM NO. 1*

**Signed:** \_\_\_\_\_ **Company:** \_\_\_\_\_

**Date:** \_\_\_\_\_

*Information contained in this document is proprietary and confidential and may not be disseminated to any party other than the intended recipient without the written consent of DTC.*

**2321 WHITNEY AVENUE SUITE 301 HAMDEN CT 06518**

203 239 4200 Ph 203 234 7376 Fax

[www.teamdte.com](http://www.teamdte.com)