

## SPECIFICATIONS FOR A REPLACEMENT STAND-BY GENERATOR

The Town of Clinton is seeking bids for replacement of its stand-by generator located at the Clinton Fire Department Glenwood Station located at 149 Glenwood Road in Clinton, CT.

Bid will include the following:

- Disconnect of Old Generator from building power circuit and prepare for removal by Town forces.
- Re-work Conduits for replacement generator and provide layout for town forces to install new pad.
- Installation of new Generator
- Installation of a new 200amp 3-phase Transfer switch to switch entire load
- Price will include delivery, installation and set-up.
- Generator will be fully operational and sized adequately to handle building load

### Minimum Generator Specifications

- KOHLER 24RCL Liquid cooled generator
- Propane powered
- Sound enclosure
- Most effective noise cancellation available
- Block Heater
- Battery charger/ Maintainer
- Battery heater
- 5 Year Comprehensive warranty